

TECHNICAL SPECIFICATIONS - PRIME RATED DIESEL GENERATOR
50 kVA to 150 kVA

1. GENERAL AND SCOPE OF SUPPLY

This section specifies the design, manufacture, supply to the site, install, testing and commissioning of one three phase, low voltage silenced type Prime rated diesel generator with auto start feature and enclosed in a factory fitted canopy at the generator manufactures work (Note-1). The generator set should be provided with main failure automatic starter, automatic change over switch which will start on failure of CEB supply (Note-2) and provide regular maintenance services free of charge during twelve (12) months warranty period.

The Generator supplier shall have accredited agency in Sri Lanka for the make of generator set offered and also shall have proven record of providing after sales services including maintenance services at least during last five years. The generator set shall be brand new, having diesel engine and alternator. The offered make & type of generator shall have satisfactory service record in Sri Lanka during last five years.

The diesel generator set shall be supplied complete with all ancillary equipment necessary for starting and running of the set, including cooling systems, fuel storage and supply system, instrumentation, control and protection arrangements, spares and special tools. The generator set and the ancillary equipment shall be installed in the generator room as indicated in the drawings. Generator body and Generator neutral shall be solidly earthed.

The set is to be reasonably self-contained to minimize the work of installation at site. The engine, alternator and cooling radiator shall be mounted on a combined underbase of stress relieved fabricated steel and engine accessories shall also be mounted on the under base where appropriate, provided that this does not result in difficulty of access for maintenance.

The set is to be mounted on suitable arrangement of antivibration mounting designed to minimize the transmission of vibration but without resulting in excessive amplitudes of movement of any parts of the set. If rubber is employed in the mounts, their design should incorporate means of preventing deterioration due oil leakages.

The generator set shall be provided with sound attenuated canopy fitted at the generators manufactures work, so that the noise level shall not exceed 80 dBA at 1m distance and 60 dBA at 10m distance from the machine at full load operating condition at any direction.

Flexible connection shall be provided to all exhaust, water, air, fuel and oil piping that leaves the engine to prevent the transmission of vibration and the fracture of the piping due to movement of the set. The choice of connections and their installation is to be such as to give long life under normal operating condition of the set.

2. STANDARDS

The following Standards apply:

- BS 5000 Part 3 - Generators to be driven by Reciprocating Internal Combustion Engines

Note-1 : The Purchaser may decide whether he requires a silenced type generator depends on site condition.

Note-2 : The Purchaser may decide whether he requires the ATS/AMF facilities with the generator set.

- BS 5514 (ISO3046) - Specification for Reciprocating Internal Combustion Engines Part 1-6
- BS 5486 (IEC 439) - Factory Built assemblies of Low Voltage Switchgear and Control Gear
- BS 4999(IEC34-1) - General requirements for Rotating Electrical Machines

If the applicable standards for the offered products are different from what is specified above, a copy each of such alternative Standards in English language shall be submitted with the offer.

3. DESIGN CRITERIA

Rated continuous output shall be not less than* kVA at 0.8 power factor at generator output terminals. (Based on 35°C ambient temperature a relative humidity of 90% and at altitude of* m MSL.)

The unit shall be capable of delivering the rated output for continuous period of not less than 12 hours at a time. It shall have overload capacity of 110% of the rated output for one hour during a period of 12 hours.

3.1 ENGINE

- Number of strokes - 4
- Speed - 1500 rpm
- Cooling - fan-cooled closed cooling water circuit
- Loading - Asynchronous motor loads of upto 100% may be switched on with a maximum admissible speed droop of twelve (12) percent.

3.2 GENERATOR

- Frequency - $50 \pm 2\%$ Hz
- Voltage - 400/230 V $\pm 5\%$ 3 phase & neutral
- Speed - 1500 rpm
- Deviation Factor of voltage wave form - 5%
- Insulation Class for rotor and stator windings - H
- Protection class of enclosure - IP 23

4. DETAIL REQUIREMENTS OF THE GENERATOR SET

4.1 ENGINE

Diesel engine shall be of a well-proven make, complying with the requirements of BS 5514 (ISO 3046). The engine shall meet all the performance requirements of the set under the specified operating conditions and shall be suitable for operation on light distillate fuel oil

Note : * To be specified by the Employer.

marketed by the Ceylon Petroleum Corporation (CPC) as 'Lanka Auto Diesel' or Diesel Fuel meeting CPC standard.

A sturdy elastic coupling shall connect the engine and the generator, and both shall be mounted on a common base plate forming part of the supply, Proven and highly effective antivibrating mountings shall be provided between base plate and concrete foundation.

The engine shall be started by 24 V starter motor engaging with the fly wheel ring gear and disengaging automatically when the engine starts. The equipment shall include an adequately rated lead/acid battery together with an automatic mains energized battery charger. The charger shall have a continuous output rating sufficient to recharge the battery from 1.8 V/cell to a fully charged condition in a period of 8 hours. The battery shall be capable of providing at least six starting cycles within a period of 5 minutes.

The engine shall be water cooled. A sectional radiator shall be provided and mounted on the combined underbase and arranged to cool the engine jacket water, lubricating oil and charge air as appropriate. Circulation of cooling water through the engine and radiator shall be by means of engine driven pump. The water circuits shall be fitted with an easily accessible drain point. The cooling fan shall be arranged to drive directly by the engine and the hot air shall ducted to suitable openings in the generator room wall. The duct shall be incorporated with a suitable flexible section to prevent the transmission of vibration from the engine and the discharge end shall be provided with louvers and an insect screen.

Lubrication of the engine shall be by means of an engine driven integral pump. The pump shall have on the suction side a coarse strainer and on the delivery side a duplex 'full flow' fine filter complete with changeover cock incorporating pressure by-passes to facilitate oil flow to the engine should the filter become blocked. The lubricating oil system capacity shall be sufficient to enable the engine to run continuously for 12 hours at any load without replenishment.

The governor of the engine shall be mechanical/electronic type and be capable of fine governing of speed to Class A2 of BSS 5514/1977, ISO 3046/IV.

The engine shall be efficiently silenced with suitable noise attenuators provided at cooling/combustion air inlets and outlets and exhaust silencers complete with interconnecting pipe and fittings. Supports for each complete system shall be of the anti-vibration type and due allowance for expansion of the exhaust system shall be made by the inclusion of expansion bellows.

Exhaust pipe shall be lagged with a removable Aluminium cladding. Exhaust pipe outlet point shall be 4m above ground level.

The engine shall be provided with following protection devices for alarm and shutting down the engine automatically.

- Low lubricating oil pressure - two stage
- Engine overspeed
- High cooling water temperature - two stage
- Over crank

4.2 GENERATOR

Generator shall comply with BS 5000 (IEC 34-1) and shall be brushless, self-exciting and self-regulating type. The exciter shall be with rotating silicon rectifiers, auxiliary exciter of permanent magnet type, damper cage, static voltage regulator and compounding equipment. The voltage regulator shall maintain its setting for long periods without adjustment. Means shall be provided for a limited degree of manual adjustment of the output voltage setting.

Generator shall be directly coupled to and share a common high bedplate with the prime mover. The degree of protection for the generator and exciter shall be not less than IP 23.

Cooling of the generator shall be by a radial-flow fan. Generator bearings shall be of the ball or roller type, rated for long life and prepacked with sufficient grease for operating over long periods without replenishment.

The stator and field windings shall consist of electrolytic copper conductors insulated throughout with Class H materials as defined in IEC 85. A generator winding temperature detector (thermistor) installed at the hottest spot and wired to give alarm and shutdown.

Thermostatically controlled tubular low-temperature heaters of sufficient rating to maintain the windings in dry condition during long periods of standstill shall be fitted in the stator casing and wired out to a terminal box on the bed plate, which in-turn shall be connected to the 230-volt single-phase supply.

Voltage regulation should be maintained within $\pm 2\frac{1}{2}\%$ from no load to full load including cold to hot variation at any power factor from 0.8 to unity.

Neutral shall be solidly earthed.

4.3 FUEL STORAGE AND TRANSFER

The following shall be supplied with the unit.

4.3.1 Base Tank

The machine shall have one integral metal fuel tank (capacity sufficient for 08 hours operation at full load but not less than 900 litres) and shall be installed in a position where any fuel leakage cannot impinge on exhaust pipe or other hot engine surfaces. The tank shall be provided with all necessary fittings including fill, vent, drain and overflow line, level indication and access for inspection and maintenance. Level switches shall be provided for the following services.

- (a) Low level alarm
- (b) High level alarm
- (c) Low level start of transfer pump
- (d) High level stop of transfer pump

4.4 CONTROL EQUIPMENT

A control cubicle fabricated with welded steel panels supported by structural steel frame, shall be provided and installed for the stand-by plant, together with all necessary inter-connections, anti-condensation heaters etc. The primary function of the control equipment shall be;

- Automatic starting and stopping of the generator on receipt of signal from main panel board
- Fault indicating and appropriate action
- Manual start and stop operations in remote and local positions.

Automatic shutdown of the set and lockout of the starting system shall result from any of the following:

- Low lubricating oil pressure
- High cooling water temperature
- Failed to start
- Engine over speed (if speed exceed 20% above normal)
- High stator temperature

The control system shall include the following:

- Overload protection
- Restricted Earth fault protection
- Visual & Audible Fault indication and alarm accept/reset
- All necessary controls needed to prevent starting of machines on momentary fluctuations of main voltage

The following equipment shall be included in the control panel:

- Voltmeter and selector switch to indicate individual phase and line voltage
- Ammeter and selector switch to indicate the line current
- Frequency meter
- Hour run counter
- Engine 'start' & 'stop' push button and lock switch
- 'Remote' & 'Local' selector switch with provision for start & stop at main panel board
- 'Auto', 'Manual' & 'Off' selector switch
- 'Emergency Stop' push button
- Mains operated battery charger of the constant potential type with MCCB, ammeter, incorporating mains failure relay
- Run indicator lamp
- Fault indicator lamp
- Audible Alarm
- Lamp test push buttons, Alarm accept and reset buttons
- Tachometer and Speed indicator
- 3 Pole MCCB with neutral link

The following engine related items shall be mounted separate from the control cubicle.

- Battery charge indicator
- Lubrication oil pressure indicator
- Cooling water temperature indicator
- Engine speed adjustment (speed droop between 0 and 6 %)
- Fuel level in integral fuel tank low
- Fuel level in integral fuel tank high
- Fuel level in main storage fuel tank low

Microprocessor Control Panel with Alphaneumerical character digital display is acceptable alternative to hardwired equipments. Microprocessor Control Panel shall incorporate all above mentioned facilities.

The Microprocessor Control Panel shall be able to connect to Standard Personal Computer to download data and information from module and to programme the Module. The tenderer shall tabulate all parameters, signals, safety devices and other facilities available in the Microprocessor Control Panel.

It should be noted that control equipments should be suitable for tropical climatic conditions so that their parameters shall not vary due to ambient temperature or aging.

5. **TESTS**

The required tests shall be carried out to show that the generator set meet the duty requirements specified.

6. **OPERATION & MAINTENANCE MANUALS**

The Operation & Maintenance manuals of equipment supplied shall be furnished with the generator set with detail diagram of wiring of equipment, frequency of lubrication, operating instructions, etc.

7. **FREE MAINTENANCE AND DEFECTS LIABILITY PERIOD**

The contractor shall provide regular maintenance services as per the manufacturer's instructions, which shall include but not limited to the following work, during the twelve (12) months warranty period.

- Inspect, clean, oil and grease where necessary
- Adjustment of machinery
- Replacement of any defective parts

Further, the contractor shall provide Emergency call back service free of charge during the warranty period.

TECHNICAL SCHEDULE – PRIME RATED DIESEL GENERATOR
50 kVA to 150 kVA

REF.		UNITS	PARTICULARS	
			As Specified	As Offered
1	<u>Diesel Engine</u>			
1.1	Manufacturer's Name			
1.2	Country of Origin			
1.3	ISO rating	kW brake		
1.4	Site rating at 35°C	kW brake		
1.5	Brake mean effective pressure at site rating	Bar		
1.6	Number of cylinders			
1.7	Bore	mm		
1.8	Stroke	mm		
1.9	Speed	rpm		
	Type of Aspiration			
1.10	Year this type was put in service			
1.11	Drop in frequency/speed when engine response to 100% load injection			
	Fuel consumption at 100% Prime rated load is less than	l/hr.		
1.12	Radiator		Clause 2	
	Applicable standard			
	Manufacturer's Name			
	Manufacturer's type No.			
	Fan tip speed	m/s		
	Fan power required	kW		
	Cooling airflow	m ³ /min		
	Cooling surface area - water	m ²		
	Cooling surface area - oil	m ²		
1.13	Cooling water system			
	Applicable standard			
	Water temperature	°C		
	Water pressure	Bar		
	System capacity	litre		
	Thermostat bypass valve type			
	Low water level switch type			
1.14	Lubricating oil system			
	Applicable standard			
	Oil pressure	Bar		
	Oil temperature	°C		
	Grade of oil			
	Sump capacity	litre		
	Oil consumption/100 hr.	litre		
	Recommended oil change	hrs.		
1.15	Engine alarms			
	Applicable standard			
	Low oil pressure setting	Bar		

REF.		UNITS	PARTICULARS	
			As Specified	As Offered
1.16	Low water level setting as % of total cooling	%		
	Water capacity			
	Overspeed setting	rpm		
	High water temperature setting	°C		
1.17	High oil pressure setting	Bar		
	Exhaust system			
	Applicable standard			
	Silencer manufacturer's name			
1.18	Type of silencer (residential or standard)			
	Exhaust temperature gauge range	°C		
	Engine governor			
	Applicable standard		Clause 2	
1.19	Manufacturer's name			
	Class of governing			
	Base Fuel tank			
	Mounted integrally with engine bed plate		Yes	
2	Capacity	litre		
	Fitted with level gauge		Yes	
	Emission Standard			
	(a) HC (Hydro Carbon)	gr/kWH		
2.1	(b) CO	gr/kWH		
	(c) NO _x	gr/kWH		
	<u>A.C. Generator</u>		Clause 4.2	
	Manufacturer's name			
2.2	Type			
2.3	Country of Origin			
2.4	Rated output	KVA		
2.5	Terminal voltage	V		
2.6	Power factor	Cosφ	0.8	
2.7	Frequency	Hz	50	
2.8	Winding Connection		star	
2.9	Weight of complete alternator	Kg		
2.10	Weight of name of heaviest single item for erection	Kg		
2.11	Applicable standard		Clause 2	
2.12	Generator mechanical protection class		IP 23	
2.13	<u>Reactances :-</u>			
	a) On short circuit when running at normal speed and voltage			
	Sub-transient reactance	%		
	Transient reactance	%		
2.14	b) Unsaturated synchronous reactance	%		
	Short circuit ratio			
	Stator insulation class			
	Stator d.c. resistance per phase at 75°C	Ohm		
2.17	Type of rotor bearings			

REF.		UNITS	PARTICULARS	
			As Specified	As Offered
2.18	Number of rotor bearings			
2.19	Method of protection against shaft currents			
2.20	Rotor critical speed(s)	rpm		
2.21	Rotor inertia	kg m ²		
2.22	Weight of rotor	kg		
2.23	Rotor winding resistance at 75°C	ohm		
2.24	Generator response for 100% load change at a low Power factor :-			
	A. Instantaneous values when at :-			
	(I) Minimum excitation	%V %A		
	(ii) Maximum excitation	%V %A		
	B. After 10 Hz when initially at :-			
	(I) Minimum excitation	%V %A		
	(ii) Maximum excitation	%V %A		
2.25	State whether stator windings are protected with embedded thermistor overloads		Yes	
2.26	State whether thermostatically controlled anti-condensation heaters are fitted in the generator		Yes	
2.27	Wattage of the heaters in item 2.27	W		
3	<u>Generator Exciter</u>			
3.1	Applicable standard		Clause 2	
3.2	Manufacturer's name			
3.3	Field winding insulation			
3.4	Field winding resistance at 75°C	ohm		
3.5	Exciter winding insulation class			
3.6	Exciter winding resistance per phase at 75°C	ohm		
3.7	Number of diodes			
3.8	Type of diodes			
3.9	Diode rated current	A		
3.10	Diode rated voltage	V		
3.11	Exciter full load current in d.c. amp	A		
3.12	State what provision has been made to suppress the field when the main circuit opens under fault conditions			
4	<u>Generator Automatic Voltage Regulator</u>			
4.1	Applicable standard		Clause 2	
4.2	Manufacturer's name			
4.3	Type			
4.4	Range of manual voltage control	V		

REF.		UNITS	PARTICULARS	
			As Specified	As Offered
5	<u>800 Amp. Generator Circuit Breaker</u>			
5.1	Applicable standard		Clause 2	
5.2	Manufacturer's Name			
5.3	Type			
5.4	Country of origin			
5.5	Rated current	A		
5.6	Rated voltage	V	400	
5.7	Breaking capacity		(mini. 35kA)	
5.8	Inherent protections provided			
	Short circuit		Yes	
	Overcurrent		Yes	
	Range of adjustment of overcurrent	% to.....%	
	Range of adjustment for under voltage	%	
6	<u>Battery</u>			
6.1	Manufacturer's name			
6.2	Type			
6.3	Electrolyte			
6.4	Voltage	V		
6.5	Capacity at 10 hour rate	Ah		
6.6	Number of cells			
6.7	Voltage per cell	V		
6.8	Normal charging rate	A		
6.9	Maximum charging rate	A		
6.10	Ampere-hour efficiency at 10 hour rate	%		
6.11	Ampere-hour efficiency at 1 hour rate	%		
6.12	Dimensions of cells	mm		
6.13	Dimensions of battery complete	mm		
6.14	Weight of cell complete with electrolyte	kg		
6.15	Total weight of battery complete	kg		
6.16	Internal resistance per cell when fully charged	ohm		
6.17	Battery voltage at end of the duty cycle	V		
7	<u>Charger</u>			
7.1	Manufacturer's name			
7.2	Type			
7.3	AC input to charger	kVA		
7.4	DC output of charger	kW		
7.5	Type of d.c. voltage control			
7.6	Range of d.c. voltage control	V		
7.7	Regulation	%		
7.8	Overall dimensions	mm		
7.9	Total weight	kg		
8	<u>Control Panels</u>			
8.1	Manufacturer's Name			

REF.		UNITS	PARTICULARS	
			As Specified	As Offered
8.2	Type			
8.3	Details of Electrical equipment			
9	<u>Maximum allowable Noise Level of the Generator Set</u>			
	At 1m distance	dB(A)	80	
	At 10m distance	dB(A)	60	

BILL OF QUANTITIES

SUPPLY, INSTALLATION, TESTING & COMMISSIONING OF PRIME RATED DIESEL GENERATOR - 50 kVA TO 150 kVA

Item No	Description	Unit	Qty	Amount Before VAT (Rs.)	Amount After VAT (Rs.)
1	Supply & Delivery Diesel Generator with Auto Start facility to the specified location.	Item	1		
2	Installation of Generator complete with Control Panel, Inter connecting cables, Exhaust pipes, Generator Earthing, Control Cabling and other accessories as per specification & drawings.	Sum			
3	Testing & Commissioning and Training of owner's staff assigned for generator operation at the site.	Sum			
	Sub Total				
	Discount if any (.....%)				
	Sub Total after Discount				
	VAT				
	Total				

Tenderer's VAT No. (if any)

Tender Amount before VAT (in words) Rupees

Tenderer's Signature :

Tenderer's Seal :

Date :